



GENERAC



Customer: CSDG

Address:

City/ State/ Zip

Contact:

Phone:

KEEPING THE LIGHTS ON SINCE 1960

R#: 18672

Test Date 5/9/2025

UNIT#4641

Engine Make/ Model: Cummins 6CTA8.3G2

Engine Spec/ Serial: 45903926

Unit Make/ Model: Cummins ONAN DGFA

Unit Spec/ Serial: J990004873

Voltage: 208

Amperage: 418

Kilowatts: 150

Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	339.1	339.3	339.5	339.8	340							340.1
Hertz/Cycles	60	30	60	60	60							60
Voltage PH1	208	208	208	208	208							208
PH2	207	207	207	207	207							207
PH3	208	208	208	208	208							208
Amperage PH1	418	418	418	418	418							
PH2	418	418	418	418	418							
PH3	418	418	418	418	418							
Kilowatts	150	150	150	150	150							
Oil Pressure	75	75	73	73	73							82
Oil Temperature												
Coolant Temperature	175°F	180°F	185°F	185°F	185°F							175°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	14	14	14	14	14							14
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	52°F	52°F	52°F	52°F	52°F							52°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Juan Cardenas

Customer Signature: _____



5/8/2025

CSDG #4641

Generator Check list

Inspection Description

- ☒ Yes ☐ No ☐ NA Check coolant level and record freeze protection: -25
- ☒ Yes ☐ No ☐ NA Visual inspection of radiator: Good
- ☒ Yes ☐ No ☐ NA Visual inspection of radiator hoses: Good
- ☒ Yes ☐ No ☐ NA Check condition of coolant hoses: Good
- ☒ Yes ☐ No ☐ NA Check condition of fuel hoses: Good
- ☒ Yes ☐ No ☐ NA Check condition of engine belts: Good
- ☒ Yes ☐ No ☐ NA Batteries and QTY: 1 24 group (Core)
- ☒ Yes ☐ No ☐ NA Battery install date if applicable: 9/16
- ☐ Yes ☒ No ☐ NA Genset has battery charger:
- ☒ Yes ☐ No ☐ NA Genset has coolant heater:
- ☒ Yes ☐ No ☐ NA Check engine oil level: Good
- ☒ Yes ☐ No ☐ NA Engine oil filters last changed date and HRS: 5/8/25, 338.2 HRS
- ☒ Yes ☐ No ☐ NA Inspect exhaust system for cracks / leaks: Good
- ☒ Yes ☐ No ☐ NA Check rain cap for proper operation: Good
- ☒ Yes ☐ No ☐ NA Generator end is 12 lead reconnectable:
- ☒ Yes ☐ No ☐ NA Generator end has PMG permanent magnet generator:
- ☒ Yes ☐ No ☐ NA Mechanical Engine: