



## Load Bank Test Report

Engine Make/ Model: Deutz BF4M 1013  
 Engine Spec/ Serial: 856638  
 Unit Make/ Model: Generac SD0060-D364.8D18EVYYC  
 Unit Spec/ Serial: 2075275

Voltage: 208  
 Amperage: 166.5  
 Kilowatts: 60  
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	7.4	7.5	7.7	8	8.2	8.5	8.6
Hertz/Cycles	62	59.8	59.6	59.4	59.2	59.3	62
Voltage PH1-N	210	209	209	208	208	208	209
PH2	210	208	208	208	207	208	208
PH3	210	208	208	208	208	208	208
Amperage PH1-N	0	162	161	161	161	161	0
PH2	0	162	161	161	161	161	0
PH3	0	162	161	161	160	160	0
Kilowatts	0	58	58	58	58	58	0
Oil Pressure	70	61	55	53	52	52	54
Coolant Temperature	67	112°F	184°F	184°F	186°F	186°F	176°F
DC Voltage	13.2	13.2	13.2	13.2	13.2	13.2	13.2
Ambient Temperature	35	36°F	36°F	37°F	37°F	37°F	37°F

Technician Signature Jonathan Mueller

Test Date 3/31/2025



**3/31/2025**

**CSDG #4670**

### **Generator Check list**

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: -30
- Yes  No  NA Visual inspection of radiator: Good
- Yes  No  NA Visual inspection of radiator hoses: Good
- Yes  No  NA Check condition of coolant hoses: Good
- Yes  No  NA Check condition of fuel hoses: Good
- Yes  No  NA Check condition of engine belts: Good
- Yes  No  NA Batteries and QTY: 1, 32 group (battery starts unit)
- Yes  No  NA Battery install date if applicable:
- Yes  No  NA Genset has battery charger:
- Yes  No  NA Genset has coolant heater:
- Yes  No  NA Check engine oil level: Good
- Yes  No  NA Engine oil filters last changed date and HRS: 3/31/25, 8 HRS
- Yes  No  NA Inspect exhaust system for cracks / leaks: Good
- Yes  No  NA Check rain cap for proper operation: Good
- Yes  No  NA Generator end is 12 lead reconnectable: (Selector Switch)
- Yes  No  NA Generator end has PMG permanent magnet generator:
- Yes  No  NA Mechanical Engine: