



**GENERAC**



Customer: CSDG  
 Address: \_\_\_\_\_  
 City/ State/ Zip \_\_\_\_\_  
 Contact: \_\_\_\_\_  
 Phone: \_\_\_\_\_

R#: \_\_\_\_\_  
 Test Date 5/16/2025  
 unit # 4722

Engine Make/ Model: JOHN DEER 6135HFG84 RE567213  
 Engine Spec/ Serial: RG6135LO30110  
 Unit Make/ Model: KOHLER 400REOZJB  
 Unit Spec/ Serial: SGM32CWK4

Voltage: 480  
 Amperage: 482  
 Kilowatts: 400  
 Power Factor 1

|                      | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | 1-1/2 Hr. | 2 Hours | 2-1/2 Hrs. | 3 Hours | 3-1/2 Hrs. | 4 Hours | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|---------|------------|---------|------------|---------|-----------|
| Eng Hours            | 189.9  | 190.2   | 190.4   | 190.7   | 190.8  |           |         |            |         |            |         | 191       |
| Hertz/Cycles         | 60     | 60      | 60      | 60      | 60     |           |         |            |         |            |         | 60        |
| Voltage PH1          | 480    | 480     | 480     | 480     | 480    |           |         |            |         |            |         | 480       |
| PH2                  | 480    | 480     | 480     | 480     | 480    |           |         |            |         |            |         | 480       |
| PH3                  | 480    | 480     | 480     | 480     | 480    |           |         |            |         |            |         | 480       |
| Amperage PH1         | 486    | 486     | 486     | 486     | 486    |           |         |            |         |            |         |           |
| PH2                  | 487    | 487     | 487     | 487     | 487    |           |         |            |         |            |         |           |
| PH3                  | 487    | 487     | 487     | 487     | 487    |           |         |            |         |            |         |           |
| Kilowatts            | 400    | 400     | 400     | 400     | 400    |           |         |            |         |            |         |           |
| Oil Pressure         | 43     | 42      | 42      | 42      | 42     |           |         |            |         |            |         | 48        |
| Oil Temperature      |        |         |         |         |        |           |         |            |         |            |         |           |
| Coolant Temperature  | 192°F  | 194°F   | 194°F   | 194°F   | 194°F  |           |         |            |         |            |         | 178°F     |
| Man Vac./Press. L/B  |        |         |         |         |        |           |         |            |         |            |         |           |
| Man Vac./Press. R/B  |        |         |         |         |        |           |         |            |         |            |         |           |
| L/B Exhaust Temp     |        |         |         |         |        |           |         |            |         |            |         |           |
| R/B Exhaust Temp     |        |         |         |         |        |           |         |            |         |            |         |           |
| Exhaust Temperature  |        |         |         |         |        |           |         |            |         |            |         |           |
| DC Voltage           | 28.6   | 28.6    | 28.6    | 28.6    | 28.6   |           |         |            |         |            |         | 28.6      |
| Natural Gas Pressure |        |         |         |         |        |           |         |            |         |            |         |           |
| Diesel Fuel Level    |        |         |         |         |        |           |         |            |         |            |         |           |
| Room Temperature     |        |         |         |         |        |           |         |            |         |            |         |           |
| Ambient Temperature  | 75°F   | 75°F    | 75°F    | 75°F    | 75°F   |           |         |            |         |            |         | 75°F      |

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Juan Cardenas

Customer Signature: \_\_\_\_\_



**5/16/25**

**CSDG #4722**

### **Generator Check list**

#### Inspection Description

- ☒ Yes ☐ No ☐ NA Check coolant level and record freeze protection: -36
- ☒ Yes ☐ No ☐ NA Visual inspection of radiator:
- ☒ Yes ☐ No ☐ NA Visual inspection of radiator hoses:
- ☒ Yes ☐ No ☐ NA Check condition of coolant hoses:
- ☒ Yes ☐ No ☐ NA Check condition of fuel hoses:
- ☒ Yes ☐ No ☐ NA Check condition of engine belts:
- ☒ Yes ☐ No ☐ NA Batteries and QTY:2 / 31 group
- ☒ Yes ☐ No ☐ NA Battery install date if applicable: 4/2024
- ☒ Yes ☐ No ☐ NA Genset has battery charger:
- ☒ Yes ☐ No ☐ NA Genset has coolant heater:
- ☒ Yes ☐ No ☐ NA Check engine oil level: Good
- ☒ Yes ☐ No ☐ NA Engine oil filters last changed date and HRS: 3/24 HR 166
- ☒ Yes ☐ No ☐ NA Inspect exhaust system for cracks / leaks:
- ☒ Yes ☐ No ☐ NA Check rain cap for proper operation:
- ☒ Yes ☐ No ☐ NA Generator end is 12 lead reconnectable:
- ☒ Yes ☐ No ☐ NA Generator end has PMG permanent magnet generator:
- ☒ Yes ☐ No ☐ NA Electronic Engine: