

**GENERAC**

Customer: CSDG

Address: _____

City/ State/ Zip _____

Contact: _____

Phone: _____

R#: _____

Test Date 4/16/2025

unit # 4723

Engine Make/ Model: JONH DEER 6090HF484

Engine Spec/ Serial: RG6090L126459

Unit Make/ Model: KOHLER 230REOZIE

Unit Spec/ Serial: SGM32GCLC

Voltage: 480

Amperage: 277

Kilowatts: 230

Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours	2-1/2 Hrs.	3 Hours	3-1/2 Hrs.	4 Hours	Cool Down
Eng Hours	1477.9	1478.1	1478.4	1478.6	1478.8							1478.9
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	480	480							480
PH2	480	480	480	480	480							480
PH3	480	480	480	480	480							480
Amperage PH1	278	27	278	278	278							
PH2	281	281	281	281	281							
PH3	279	279	279	279	279							
Kilowatts	230	230	230	230	230							
Oil Pressure	56	50	42	41	41							44
Oil Temperature												
Coolant Temperature	171°F	175°F	181°F	183°F	183°F							174°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	2.5	28.5	28.5	28.5	28.5							28.5
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	72°F	72°F	72°F	72°F	72°F							72°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Juan Cardenas

Customer Signature: _____



5/16/2025

CSDG #4723

Generator Check list

Inspection Description

- ☒ Yes ☐ No ☐ NA Check coolant level and record freeze protection: -40
- ☒ Yes ☐ No ☐ NA Visual inspection of radiator:
- ☒ Yes ☐ No ☐ NA Visual inspection of radiator hoses:
- ☒ Yes ☐ No ☐ NA Check condition of coolant hoses:
- ☒ Yes ☐ No ☐ NA Check condition of fuel hoses:
- ☒ Yes ☐ No ☐ NA Check condition of engine belts:
- ☒ Yes ☐ No ☐ NA Batteries and QTY: 2--31GROUP
- ☒ Yes ☐ No ☐ NA Battery install date if applicable: 9/21 starts unit
- ☒ Yes ☐ No ☐ NA Genset has battery charger:
- ☒ Yes ☐ No ☐ NA Genset has coolant heater:
- ☒ Yes ☐ No ☐ NA Check engine oil level: Good
- ☒ Yes ☐ No ☐ NA Engine oil filters last changed date and HRS: 5/16/24, 1357HRS
- ☒ Yes ☐ No ☐ NA Inspect exhaust system for cracks / leaks:
- ☒ Yes ☐ No ☐ NA Check rain cap for proper operation:
- ☒ Yes ☐ No ☐ NA Generator end is 12 lead reconnectable:
- ☒ Yes ☐ No ☐ NA Generator end has PMG permanent magnet generator:
- ☒ Yes ☐ No ☐ NA Electronic Engine: