



Load Bank Test Report

Engine Make/ Model: John deere 6068HFG85
Engine Spec/ Serial: PE6068L957906
Unit Make/ Model: DS200
Unit Spec/ Serial: 95090601147

Voltage: 480
Amperage: 240
Kilowatts: 200
Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	35.38	35.41	35.56	36.11	36.16	36.31	36.41
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	478	478	478	478	478	480
PH2	480	478	478	478	477	478	480
PH3	480	478	479	478	479	479	480
Amperage PH1	0	245	245	245	246	245	0
PH2	0	246	246	245	245	245	0
PH3	0	245	246	246	246	246	0
Kilowatts	0	200	200	200	200	200	0
Oil Pressure	74	70	64	65	64	65	68
Coolant Temperature	75	104°F	183°F	183°F	182°F	183°F	170°F
DC Voltage	13	13.4	13.4	13.4	13.4	13.4	13.5
Ambient Temperature	50	50°F	50°F	50°F	50°F	50°F	50°F

Technician Signature *Dylan Gottschalk*

Test Date 2/18/2026



2/18/2026

CSDG #4724

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -30
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses:
- Yes No NA Check condition of fuel hoses:
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY: 1, group 24 (good)
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 34Hrs, 5-20-25
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: