



Load Bank Test Report

Engine Make/ Model: Cummins QSK60-G14
Engine Spec/ Serial: 33211720
Unit Make/ Model: Cummins DQKAF-1736445
Unit Spec/ Serial: D180348367

Voltage: 480
Amperage: 2679.4
Kilowatts: 2250
Power Factor: 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	183.3	183.4	183.6	183.9	184.1	184.4	184.5
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480	480
PH2	480	480	480	480	480	480	480
PH3	480	480	480	480	480	480	480
Amperage PH1	0	2616	2617	2624	2623	2633	0
PH2	0	2712	2714	2717	2716	2718	0
PH3	0	2725	2726	2732	2733	2703	0
Kilowatts	0	2225	2225	2232	2230	2225	0
Oil Pressure	105	64	64	63	65	65	70
Coolant Temperature	66	185°F	186°F	187°F	187°F	187°F	171°F
DC Voltage	26.5	27.5	27.5	27.4	27.6	27.7	27.5
Ambient Temperature	68	68°F	68°F	68°F	68°F	68°F	68°F

Technician Signature Jonathan Mueller

Test Date 10/17/2025



10/17/2025

CSDG #4773

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses
- Yes No NA Check condition of coolant hoses
- Yes No NA Check condition of fuel hoses
- Yes No NA Check condition of engine belts
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS: 10/16/2025, 182hrs
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable: (6 lead)
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: