



Load Bank Test Report

Engine Make/ Model: Cummins QSL9-G2-NR3
Engine Spec/ Serial: 46720720
Unit Make/ Model: DSHAA
Unit Spec/ Serial: B070023812

Voltage: 480
Amperage: 180
Kilowatts: 150
Power Factor: 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	44.6	44.7	44.9	45.1	45.3	45.5	45.6
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	481	481	480	480	481	480
PH2	480	481	481	480	481	481	480
PH3	480	480	481	480	480	481	480
Amperage PH1	0	180	180	180	180	180	0
PH2	0	181	181	180	181	180	0
PH3	0	180	180	180	181	181	0
Kilowatts	0	151	151	152	152	151	0
Oil Pressure	85	73	64	58	55	56	62
Coolant Temperature	77	120°F	175°F	177°F	176°F	176°F	165°F
DC Voltage	24.5	24.6	24.7	24.6	24.6	24.7	24.7
Ambient Temperature	37	37°F	37°F	37°F	37°F	37°F	37°F

Technician Signature Dylan Gottschalk

Test Date 1/8/2026



1/8/2026

CSDG #4817

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses:
- Yes No NA Check condition of fuel hoses:
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY:2 (good) group 24
- Yes No NA Battery install date if applicable: 11/25
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level: Good
- Yes No NA Engine oil filters last changed date and HRS: 1/8/26, 45HRS
- Yes No NA Inspect exhaust system for cracks / leaks
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: