



12/2/2025

CSDG #4882

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -50 (Added 4gal)
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses
- Yes No NA Check condition of fuel hoses
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY: 2, 4D (Cores)
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS 12/2/2025, 1139HRS
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Mechanical Engine:

