



Load Bank Test Report

Engine Make/ Model: Cummins QSK50-G4
Engine Spec/ Serial: 25363491
Unit Make/ Model: Cummins DQGAB-6630738
Unit Spec/ Serial: E110215517 / C

Voltage: 480
Amperage: 1806.4
Kilowatts: 1500
Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	231.6	231.7	231.9	232.2	232.5	232.7	232.8
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	481	479	479	480	479	479	480
PH2	481	479	479	479	479	479	480
PH3	481	479	479	479	479	479	480
Amperage PH1	0	1798	1794	1802	1802	1798	0
PH2	0	1830	1826	1830	1829	1825	0
PH3	0	1793	1794	1806	1809	1804	0
Kilowatts	0	1523	1523	1522	1528	1526	0
Oil Pressure	86	86	80	78	77	77	89
Coolant Temperature	84	178°F	180°F	181°F	181°F	181°F	138°F
DC Voltage	27.1	27.1	27.1	27.1	27.1	27.1	27.1
Ambient Temperature	47	47°F	47°F	47°F	47°F	47°F	47°F

Technician Signature Jonathan Mueller

Test Date 2/19/2026



2/19/2026

CSDG #4893

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses
- Yes No NA Check condition of fuel hoses
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY: 4, 8D's (Cores)
- Yes No NA Battery install date if applicable: 5/19/21
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS:
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable: (6 lead)
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: