



Load Bank Test Report

Engine Make/ Model: Cummins QSK50-G4
Engine Spec/ Serial: 25364170
Unit Make/ Model: Cummins DQGAB-6630740
Unit Spec/ Serial: E110216880

Voltage: 480
Amperage: 1806.4
Kilowatts: 1500
Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	227.4	227.5	227.8	228	228.3	228.5	228.6
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	481	480	480	480	480	480	480
PH2	481	479	479	479	479	479	480
PH3	481	481	481	481	480	481	480
Amperage PH1	0	1784	1784	1781	1783	1782	0
PH2	0	1831	1826	1826	1823	1825	0
PH3	0	1763	1764	1764	1764	1764	0
Kilowatts	0	1513	1515	1514	1512	1513	0
Oil Pressure	101	83	75	74	75	74	85
Coolant Temperature	106	174°F	183°F	183°F	183°F	183°F	167°F
DC Voltage	26.2	26.2	26.4	26.4	26.5	26.5	26.5
Ambient Temperature	55	55°F	56°F	56°F	56°F	56°F	56°F

Technician Signature Jonathan Mueller

Test Date 2/18/2026



2/18/2026

CSDG #4894

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses
- Yes No NA Check condition of fuel hoses
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY: 4, 8D's (Starts Unit)
- Yes No NA Battery install date if applicable: 5/19/21
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS:
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable: (6 lead)
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: