



Load Bank Test Report

Engine Make/ Model: John Deere 6090HF484
 Engine Spec/ Serial: RG6090L152996
 Unit Make/ Model: JD250-02
 Unit Spec/ Serial: 122904-1-1

Voltage: 480
 Amperage: 375
 Kilowatts: 250
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	0.36	0.39	0.54	1.09	1.14	1.29	1.36
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480	480
PH2	480	480	480	480	480	480	480
PH3	480	480	480	480	480	480	480
Amperage PH1	0	375	376	375	375	376	0
PH2	0	376	376	375	376	376	0
PH3	0	375	376	376	375	376	0
Kilowatts	0	250	250	250	250	250	0
Oil Pressure	58	50	45	45	38	38	41
Coolant Temperature	80	152°F	178°F	178°F	181°F	181°F	175°F
DC Voltage	13	13	13	13	13	13	13
Ambient Temperature	69	69°F	69°F	69°F	69°F	69°F	69°F

Technician Signature Dylan Gottschalk

Test Date 6/25/2026



6/25/2026

CSDG #4895

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -35
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses:
- Yes No NA Check condition of fuel hoses:
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY:1 8D GOOD
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS 6/26/26 1.36Hrs
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: