



Load Bank Test Report

Engine Make/ Model: Cummins QSK50-G4
Engine Spec/ Serial: 33180312
Unit Make/ Model: DQAGG-3395061
Unit Spec/ Serial: A / C100108254

Voltage: 480
Amperage: 1505.3
Kilowatts: 1250
Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	647	648	648	648	648	649	649
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	479	479	479	479	479	480
PH2	480	479	479	478	478	479	480
PH3	480	480	480	480	480	480	480
Amperage PH1	0	1520	1521	1529	1529	1526	0
PH2	0	1456	1454	1463	1463	1526	0
PH3	0	1454	1452	1459	1459	1458	0
Kilowatts	0	1250	1250	1250	1250	1250	0
Oil Pressure	100	83	75	73	75	74	85
Coolant Temperature	91	158°F	172°F	174°F	172°F	172°F	138°F
DC Voltage	26.4	26.6	26.8	26.9	27	27	27
Ambient Temperature	22	22°F	22°F	22°F	22°F	22°F	22°F

Technician Signature DYLAN GOTTSCHALK

Test Date 1/21/2026



1/21/2026

CSDG #4915

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -30
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses:
- Yes No NA Check condition of fuel hoses:
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY:4 8d (Core)
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS:
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: