



Load Bank Test Report

Engine Make/ Model: VTA28-G5
 Engine Spec/ Serial: 25300077
 Unit Make/ Model: DFGB
 Unit Spec/ Serial: C050759935

Voltage: 480
 Amperage: 722
 Kilowatts: 600
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	732.9	733	733.2	733.4	733.6	733.8	734
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480	480
PH2	480	480	480	480	480	480	480
PH3	480	480	480	480	480	480	480
Amperage PH1	0	721	722	721	721	722	0
PH2	0	721	722	721	722	722	0
PH3	0	722	722	721	722	722	0
Kilowatts	0	600	600	600	600	600	0
Oil Pressure	85	73	64	65	64	65	69
Coolant Temperature	82	100°F	169°F	182°F	182°F	182°F	178°F
DC Voltage	27.8	27.9	27.9	28	28	28	28
Ambient Temperature	70	70°F	70°F	70°F	70°F	70°F	70°F

Technician Signature *Dylan Gottschalk*

Test Date 4/15/2026



4/14/2026

CSDG #4924

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -40
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses:
- Yes No NA Check condition of fuel hoses:
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY: 4 4D (CORE)
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Mechanical Engine: