



Load Bank Test Report

Engine Make/ Model: Volvo Penta TAD1241GE
 Engine Spec/ Serial: 99062309
 Unit Make/ Model: 350REOZV
 Unit Spec/ Serial: 2072095

Voltage: 480
 Amperage: 421
 Kilowatts: 350
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	301.1	301.2	301.4	301.6	301.8	302	302.2
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480	480
PH2	480	480	480	480	480	480	480
PH3	480	480	480	480	480	480	480
Amperage PH1	0	422	422	423	422	422	0
PH2	0	422	421	421	422	421	0
PH3	0	421	421	422	422	421	0
Kilowatts	0	350	350	350	350	350	0
Oil Pressure	65	60	55	55	55	55	58
Coolant Temperature	95	160°F	210°F	210°F	210°F	210°F	189°F
DC Voltage	25	25	25	25	25	25	25
Ambient Temperature	74	74°F	74°F	74°F	74°F	74°F	74°F

Technician Signature Dylan Gottschalk

Test Date 6/23/2026



6/23/2026

CSDG #4953

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -30
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses:
- Yes No NA Check condition of fuel hoses:
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY:
- Yes No NA Battery install date if applicable:
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS 7/8/24 286.4 hrs
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: