



Load Bank Test Report

Engine Make/ Model: Cummins QSK23-G7-NR2
Engine Spec/ Serial: 85000829
Unit Make/ Model: DQCB
Unit Spec/ Serial: B150797060

Voltage: 480
Amperage: 902
Kilowatts: 750
Power Factor: 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	432.5	432.6	432.8	433	433.2	433.4	433.6
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	480	478	480	478	479	480
PH2	480	479	480	479	479	479	480
PH3	480	478	478	479	479	479	480
Amperage PH1	0	875	876	876	876	876	0
PH2	0	877	877	877	876	877	0
PH3	0	877	877	876	876	876	0
Kilowatts	0	750	750	750	750	750	0
Oil Pressure	83	77	61	61	59	60	63
Coolant Temperature	85	142°F	169°F	170°F	170°F	170°F	161°F
DC Voltage	27.3	27.5	27.5	27.6	27.5	27.5	27.5
Ambient Temperature	65	65°F	65°F	65°F	65°F	65°F	65°F

Technician Signature Dylan Gottschalk

Test Date 3/25/2026



3/25/2026

CSDG #4978

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -45
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses:
- Yes No NA Check condition of fuel hoses:
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY: 2 4D
- Yes No NA Battery install date if applicable: 2023
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS 414 4/10/25
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: