



Load Bank Test Report

Engine Make/ Model: GM/5.7L
 Engine Spec/ Serial: 5.7L24667
 Unit Make/ Model: Kohler/ 100REZGD
 Unit Spec/ Serial: SGM322BN6

Voltage: 277/480
 Amperage: 120
 Kilowatts: 100KW
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	406.7	406.7	406.9	407.1	407.4	407.7	407.7
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480	480
PH2	481	481	481	482	481	481	481
PH3	481	481	480	481	481	481	481
Amperage PH1	0	123	124	124	124	124	0
PH2	0	133	133	133	133	133	0
PH3	0	124	124	124	123	123	0
Kilowatts	0	95	95	95	95	95	0
Oil Pressure	56	54	51	50	49	48	50
Coolant Temperature	135	156°F	159°F	162°F	165°F	175°F	156°F
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1	14.1
Ambient Temperature	58	62°F	64°F	73°F	77°F	78°F	74°F

Technician Signature Grant Busse

Test Date 4/1/2026