



## Load Bank Test Report

Engine Make/ Model: Cummins QSL9-G2  
 Engine Spec/ Serial: 46525369  
 Unit Make/ Model: DSHAC  
 Unit Spec/ Serial: J050845933

Voltage: 480  
 Amperage: 240  
 Kilowatts: 200  
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	347.8	347.9	348.1	348.3	348.5	348.7	348.8
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480	480
PH2	480	480	480	480	480	480	480
PH3	480	480	480	480	480	480	480
Amperage PH1	0	239	239	239	240	239	0
PH2	0	241	240	240	240	240	0
PH3	0	239	240	240	239	240	0
Kilowatts	0	200	200	200	200	200	0
Oil Pressure	85	73	70	65	61	61	65
Coolant Temperature	80	150°F	187°F	187°F	187°F	187°F	178°F
DC Voltage	13.6	13.6	13.7	13.7	13.6	13.7	13.7
Ambient Temperature	66	66°F	66°F	66°F	66°F	66°F	66°F

Technician Signature *Dylan Gottschalk*

Test Date 6/22/2026



**6/22/2026**

**CSDG #4988**

### **Generator Check list**

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: -30
- Yes  No  NA Visual inspection of radiator:
- Yes  No  NA Visual inspection of radiator hoses:
- Yes  No  NA Check condition of coolant hoses:
- Yes  No  NA Check condition of fuel hoses:
- Yes  No  NA Check condition of engine belts:
- Yes  No  NA Batteries and QTY: 2 group31 core
- Yes  No  NA Battery install date if applicable:
- Yes  No  NA Genset has battery charger:
- Yes  No  NA Genset has coolant heater:
- Yes  No  NA Check engine oil level:
- Yes  No  NA Engine oil filters last changed date and HRS 3/10/26 347.8hrs
- Yes  No  NA Inspect exhaust system for cracks / leaks:
- Yes  No  NA Check rain cap for proper operation:
- Yes  No  NA Generator end is 12 lead reconnectable:
- Yes  No  NA Generator end has PMG permanent magnet generator:
- Yes  No  NA Mechanical Engine: