

Load Test Report

Test Information

Customer	Asset ID	Location	Date	Technician	Load %	Ambient Temp.	Hours Before	Hours After	Duration	Min. Record Intervals
MEG	MEG1298	Shop	4/17/2026	Rylie West	100.00%	60	288	289	1 Hour	15 Minutes

Pre Startup Checks

Generator Information

Check engine oil level	Check coolant level	Verify generator & load bank voltage connection	Confirm ground connection	Ensure circuit breaker is open (OFF)	Engine Mfg.	Engine Model	Engine Serial #	Package Serial #	Control Panel	kW	RPM	PF
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Cummins	QST30-G5 NR2	37262321	I140743801	3201	1000	1800	1.00

Time	Volts			Amps			Freq. Hz	Boost PSI	Load kW	Cool Temp (°F)	Lube Oil	Fuel Press	% of Load	Battery Voltage
	1	2	3	1	2	3								
9:00 AM	480	480	480	316	320	315	60	20	266	150	65	65	26.60%	26
9:15 AM	479	480	480	552	557	559	60	29	461.9	172	56	70	46.19%	26
9:30 AM	480	480	480	850	853	856	60	40	709.2	172	54	69	70.92%	26
9:45 AM	480	480	480	1120	1147	1123	60	50	939.5	173	53	65	93.95%	26
10:00 AM Cooldown	480	480	480	0	0	0	60	14.7	0	170	56	62	0.00%	26
-													0.00%	
-													0.00%	
-													0.00%	
-													0.00%	
Cooldown	alternator on unit								#DIV/0!					



Load Test Report Revision Log

Date	Revision	Description
10/15/2025	IDP	Document created and published by Cody Herman and Ian Gjertson.