



Load Bank Test Report

Engine Make/ Model: Cummins / NTA-855-G5
Engine Spec/ Serial: 33072/ 30363560
Unit Make/ Model: Cummins / DFCE
Unit Spec/ Serial: D/ K990020375

Voltage: 277/480
Amperage: 481 @1.0PF
Kilowatts: 400KW
Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1020.2	1020.3	1020.5	1020.8	1021	1021.3	1021.4
Hertz/Cycles	59.9	59.9	59.9	59.9	59.9	59.9	59.9
Voltage PH1	481	481	481	481	481	481	481
PH2	484	484	484	484	484	484	484
PH3	481	481	481	481	481	481	481
Amperage PH1	0	479	479	479	479	479	0
PH2	0	481	481	481	481	481	0
PH3	0	481	481	481	481	481	0
Kilowatts	400	400	400	400	400	400	0
Oil Pressure	44	43	42	39	39	39	41
Coolant Temperature	102	122°F	159°F	159°F	159°F	159°F	155°F
DC Voltage	27.7	27.7	27.8	27.8	27.8	27.8	27.8
Ambient Temperature	52	52°F	53°F	54°F	54°F	54°F	54°F

Technician Signature GRANT BUSSE

Test Date 4/27/2026