



Load Bank Test Report

Engine Make/ Model: PSI Doosan / D183L
Engine Spec/ Serial: SN:EZS0D600690
Unit Make/ Model: Kohler / 300REZXB
Unit Spec/ Serial: GM99509-GA1 / SGM32JGFM

Voltage: 277/480
Amperage: 360 1.0PF
Kilowatts: 300
Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	547.1	547.2	547.5	547.7	548	548.2	548.4
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	479	479	479	479	479	479	479
PH2	478	478	478	478	478	478	478
PH3	480	480	480	480	480	480	480
Amperage PH1	0	357	357	357	357	357	0
PH2	0	358	358	358	358	358	0
PH3	0	355	355	355	355	355	0
Kilowatts	0	298	298	298	298	298	0
Oil Pressure	102	99	96	96	96	96	97
Coolant Temperature	121	155°F	176°F	176°F	176°F	176°F	174°F
DC Voltage	28.7	28.7	28.7	28.7	28.8	28.8	28.8
Ambient Temperature	57	57°F	57°F	57°F	57°F	57°F	57°F

Technician Signature Grant Busse

Test Date 4/27/2026