



Customer: Central States Diesel Generators STK#5047
Address: 2001 S Prairie Ave.
City/ State/ Zip Waukesha, WI 53189
Contact: Patrick Paden
Phone: 262-955-7655

Test Date 7-23-26

Engine Make/ Model: Cummins QSB7-G5 NR3
Engine Spec/ Serial: 73395648
Unit Make/ Model: Cummins DSGAA
Unit Spec/ Serial: E120335637

Voltage: 277/480
Amperage: 120
Kilowatts: 100
Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	187.2	187.4	187.7	187.9	188.2	188.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	481	481	481	481	481	481
Amperage PH1	0	122	122	122	122	0
PH2	0	121	121	122	121	0
PH3	0	122	122	121	122	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	59	55	55	55	55	59
Oil Temperature						
Coolant Temperature	175°F	179°F	179°F	179°F	179°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	82°F	82°F	82°F	82°F	82°F	82°F

Technician Signature: Tim Graves

Customer Signature: _____