



Load Bank Test Report

Engine Make/ Model: Cummins QSL9-G2 NR3
 Engine Spec/ Serial: 49852910
 Unit Make/ Model: DSHAA
 Unit Spec/ Serial: B080154040

Voltage: 480
 Amperage: 180
 Kilowatts: 150
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	500	500.1	500.3	500.5	500.7	500.9	501
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480	480
PH2	480	480	480	480	480	480	480
PH3	480	480	480	480	480	480	480
Amperage PH1	0	180	181	180	181	180	0
PH2	0	179	180	180	179	180	0
PH3	0	180	181	180	180	180	0
Kilowatts	0	150	150	150	150	150	0
Oil Pressure	90	83	75	70	70	70	73
Coolant Temperature	78	102°F	185°F	185°F	187°F	187°F	168°F
DC Voltage	13	13	13	13	13	13	13
Ambient Temperature	81	81°F	81°F	81°F	81°F	81°F	81°F

Technician Signature *Dylan Gottschalk*

Test Date 7/7/2026



7/7/2026

CSDG #5067

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: -30
- Yes No NA Visual inspection of radiator:
- Yes No NA Visual inspection of radiator hoses:
- Yes No NA Check condition of coolant hoses:
- Yes No NA Check condition of fuel hoses:
- Yes No NA Check condition of engine belts:
- Yes No NA Batteries and QTY:2 Group 36
- Yes No NA Battery install date if applicable: 2026
- Yes No NA Genset has battery charger:
- Yes No NA Genset has coolant heater:
- Yes No NA Check engine oil level:
- Yes No NA Engine oil filters last changed date and HRS 7/7/26
- Yes No NA Inspect exhaust system for cracks / leaks:
- Yes No NA Check rain cap for proper operation:
- Yes No NA Generator end is 12 lead reconnectable:
- Yes No NA Generator end has PMG permanent magnet generator:
- Yes No NA Electronic Engine: