

# STOWERS POWER SYSTEMS

# LOAD BANK REPORT

# KNOXVILLE

ENGINE MAKE

GENERATOR MAKE

Customer Name

MODEL

MODEL

SERIAL #

SERIAL #

Customer Equip #

Standby

Prime

HRS Before

HRS After

KW

VOLTS

Rated Amps @ .8

WO #

Test Hours	^T Rad	Water Temp	Exh Temp	Fuel PSI	Oil Press	RPMs	Hz	VOLTS L-L			Volts	VOLTS L-N			PF	AMPS			Amps	KW	Load %
								AB	BC	CA		A	B	C		A	B	C			
WarmUp		111	390	267	47	1800	60	480	480	480	480	277	277	277	1	0	0	0	0	0	0.0%
BeginTest		168	454	267	45	1800	60	480	480	480	480	277	277	277	1	547	550	548	548	456	101.3%
15 Min		171	569	268	43	1800	60	480	480	480	480	277	277	277	1	546	551	547	548	456	101.2%
30 Min		174	620	268	41	1800	60	480	480	480	480	277	277	277	1	547	551	546	548	456	101.2%
45 Min		176	625	267	38	1800	60	480	480	480	480	277	277	277	1	549	551	545	548	456	101.3%
60 Min		176	620	268	38	1800	60	480	480	480	480	277	277	277	1	549	550	546	548	456	101.3%
CoolDown		168	400	267	39	1800	60	480	480	480	480	277	277	277	1	0	0	0	0	0	0.0%
00:00		0	0	0	0	0	0	0	0	0	0	0	0	0		0	0	0	0	0	0.0%

REMARKS

Tested by: THOMAS FRENCH - 5004

Title: GENERATOR TECH

DATE: April 8, 2026