



Critical Power Services LLC
16824 Hickory Heights Dr
Maribel WI 54227
(920) 370-8909
criticalpowerservicesllc.com

Load Bank Test Report

Engine Make/ Model: Generac SCI13GT525D 14.2L
Engine Spec/ Serial: G9152000747
Unit Make/ Model: Generac / SG0300
Unit Spec/ Serial: 9764839

Voltage: 120/208 3 phase
Amperage: 833
Kilowatts: 300
Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	193.1	193.2	193.5	193.7	194	194.2	194.3
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208	208
PH2	208	208	208	208	208	208	208
PH3	208	208	208	208	208	208	208
Amperage PH1	0	827	827	826	826	826	0
PH2	0	830	830	830	830	829	0
PH3	0	831	831	831	831	831	0
Kilowatts	0	299	299	299	299	299	0
Oil Pressure	82	81	80	79	78	78	79
Coolant Temperature	118	169°F	173°F	173°F	173°F	173°F	170°F
DC Voltage	27.1	27.1	27.1	27.1	27.1	27.1	27.1
Ambient Temperature	85	86°F	86°F	86°F	87°F	88°F	88°F

Technician Signature GRANT BUSSE

Test Date 7/11/2026